


one quarter

Revisions:

VA FORM 08-6231

Associates, Inc.

Date



(This Drawing)

- THE CONTRACTOR SHALL BE RESPONSIBLE FOR PROVIDING ALL NECESSARY WIRING, CIRCUITS, CONNECTIONS, MODIFICATIONS TO THE EXISTING FIRE ALARM EQUIPMENT, AND DEVICES FOR THE PROPER INTEGRATION OF ALL ELEVATORS IMPACTING THE FIRE FIGHTERS PHASE I OPERATION.
- (2) REFER TO DRAWING E601 FOR FIRE ALARM REQUIREMENTS FOR ELEVATOR AND MACHINE ROOM.
- 3 ADDRESSIBLE FIRE ALARM CONTROL PANEL FOR DEVICES ON THIS FLOOR, AND NEW DEVICES ON THE
- FIRE ALARM POWER SUPPLY CABINET FOR DEVICES ON THIS FLOOR AND NEW DEVICES ON THE BASEMENT AND FIRST FLOOR.



Project Number 542-13-105 Office of AND SECOND FLOOR SECOND FLOOR RENOVATION Construction **Building Number** and Facilities A E works Location: 1400 Blackhorse Hill Road Coatesville, PA 19320 **Drawing Number** Approved: Project Director Management EF102 6587 HAMILTON AVENUE PITTSBURGH, PENNSYLVANIA 15206 PH: 412.287.7333 FAX: 412.287.7334 Checked Drawn Department of Veterans Affairs 05 / 12 / 14 JJD JMZ **Dwg**. 119 **of** 12 www.ae-works.com